## 2024 CODE CHANGE PROPOSAL GROUP A PROCESS: IMC

Proposal #	Part #	Committee	Primary Code Section	Topic: General info on what the proposal is about. Example-The proposal is on Fire Walls	your recommendation identified in Column F. Add your initials to your comments for tracking	Support: N-	CAH#1 W-Watch; T-Testify NA-No Action	CAH#1 results: AS= as submitted, AM by: As modified by, D= Disapproval	Vote	CAH#1 results Summary	OBOA CAH#1 Comments
		Mechanical Code			Allowing only a receiver for attaching a	_		_		Proposal introduced new code language that the committee unanimously agreed was unenforceable code	
M17-24 M22-24		Committee Mechanical Code Committee	401.1, 401.2, SECTION 403, 403.1, 403.3, 403.3.1, 403.3.2, 403.3.2.1, 403.3.2, 403.3.2.3, TABLE 403.3.2.3		specialized ladder this is not the intent of code Good changes however, the layout now seems dwelling unit centric. It should be rewritten with general requirements and exceptions for other specific uses that specific design requirements apply.	s	w		14-0	language. Proposal does not make clear the current ventilation requirements.	
M25-24 Part I		Mechanical Code Committee	401.2.1 (New), 502.21 (New), 502.21.1 (New), 502.21.2 (New), 502.21.3 (New), 502.21.4 (New)	Hazardous exhaust requirments	???? Need to look into this further why is brake glass push button not indicated and even ignored, but the addition of efficient is a positive thing for these considerations	N	w	AS	14-0	Requirements based on best practices and ensure basic fire and life safety measures.	
M41-24		Mechanical Code Committee	506.3.2.5	Grease duct test. A	up for discussion not sure it's really necessary to remove the light test that has been used effectively for quite a while, but I would not be dismissive if the board and experience by inspectors that it is not effective	0	w	D	14-0	A light test is usually more effective, and this proposal removes a methodology commonly approved.	