## 2024 CODE CHANGE PROPOSAL GROUP A PROCESS: IRC PLUMBING

Proposal #	Part #	Committee	Primary Code Section	Tonic: General info on	Comments: Provide a brief overview of the proposal. Include a short reason on your recommendation identified in Column F. Add your initials to your comments for tracking.	Support; N-	T-Testify NA-No	CAH#1 results: AS= as submitted, AM by: As modified by, D= Disapproval	Vote	CAH#1 results Summary	OBOA CAH#1 Comments
P19-24	II	egress?	Table 1004	occupant load for pools	Increase occupant loads for pools	W	W	AS			
P22-24			2902.1.1	calculation language for all- gender	Adjusts language for calculating all-gender restrooms. more clear for reference to accessible stall requirements	S	W	AS			
P25-24			2902.2	separate facilites	Removes requirement for separate facilities.		W	AS			
P30-24			IPC 405.3	privacy	sets requirement for premanufacutured stalls to meet certain standards. JTO - But doesn't identify prescriptive privacy requirements for all "privacy stalls", only the premanufacutred ones? And I don't like that it references a different standard rather than putting those dimensional requirements into the code where we can vote on them.  But G28-24 for a similar thing in IBC chapter 12 passed.	o	w	D			