2024 CODE CHANGE PROPOSAL GROUP A PROCESS: IRC MECHANICAL

Proposal #	Part #	Committee	Primary Code Section	what the proposal is about. Example-The		Support; N- Neutral: O-	T-Testify NA-No	CAH#1 results: AS= as submitted, AM by: As modified by, D= Disapproval	Vote		OBOA CAH#1 Comments
RM1-24		Plumbing/Mechanical Code Committee	M1305.1.2.2	Permanent service access in attics	Required ladder or stairs to be added in new construction	so	W	D		Cost estimate was way off. Practicality of the proposal simply does not work.	
RM6-24		Plumbing/Mechanical Code Committee	M1505.4.1	Whole house ventilation	Alleviates requirements for combination supply in exhaust for climate zones 0-5	S	W	D		Proposal has too many restrictions.	